

Emission Test Certificate

Tuesday, May 5th 2015

Supplier: Premium Floors Australia (7/14 Rodborough Rd, French's Forest, Sydney, NSW 2086)

Sample Description: Titan 12 mm Laminate

Date Tested: April 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Design v3 IEQ-13	Titan 12 mm Laminate
Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.026 mg/m ² /hr
4-phenylcyclohexene Emission Rate limit <0.05mg/m ² /hr	4-phenylcyclohexene Emission Rate: <0.008 mg/m ² /hr
Formaldehyde Emission Rate limit <0.1mg/m ² /hr	Formaldehyde Emission Rate: 0.077mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BEng (Chemical Engineer)
Laboratory Technician

CV150422